

BEGGARS BUSH BARRACKS.

MAINS & DISTRIBUTION POINTS AS CHECKED & TESTED NOVEMBER 1921.

TOTAL NUMBER OF LAMPS INSTALLED IN BEGGARS BUSH BARRACKS ON 30.11.1921. "594".



FITTINGS IN GUARD ROOM CONTROL BOX.

- 1 METER, 1 D.P.S., D.P.F., FOR C.R.E.'S PRINTING ARC LAMP.
- D.P.S., D.P.F., FOR GUARD ROOM BLOCK.
- 3 S.P.F. FUSES.
- 2 D.P.S. CONTROL YELLOW & GREEN OUTERS.
- 2 METERS.
- 3 S.P.F. FUSES.
- 1 PILOT LAMP.

FITTINGS IN METER HOUSE EASTERN CORNER.

- 3 S.P.F.
- 2 D.P.S.
- 2 METERS.
- 3 S.P.F.
- 1 PILOT LAMP.

REFERENCE.

INTERNAL AND SMALL FEED WIRES.	SHEWN THUS.	—
TOP OUTER MAIN.	" "	—
NEUTRAL MAIN.	" "	—
BOTTOM OUTER MAIN.	" "	—
DISTRIBUTION POINTS.	" "	■
INSULATORS.	" "	○

SUPPLY
PEMBROKE U.D. COUNCIL.
ELECT. SUPPLY 3 WIRE SYSTEM,
440 VOLTS OUTERS.
UNDERGROUND MAIN FROM
SHELBOURNE ROAD.